

CB Series

Carbon Block Cartridges



Carbon Block Cartridges

The Puretec CB Series cartridges are highly effective in reducing, taste, odour, chlorine, and sediment. Cyst, lead, heavy metal, high turbidity and sulphur removal models are also available. The Puretec CB cartridges are constructed from bonded activated carbon, offering superior treatment of water with no release of carbon fines.

Specifications

	Model	Dimensions	Description	Flow (Lpm)	Micron Rating*	Chlorine Capacity* L
5"	CB955	Standard 2.5" x 5"	cyst reduction*	8	0.5	38,283 L
10"	CB951	Standard 2.5" x 10"	cyst reduction*	15	0.5	75,708 L
	CB951-H	Standard 2.5" x 10"	cyst and heavy metal reduction*	15	0.5	75,708 L
	CB051	Standard 2.5" x 10"		16	5	64,352 L
	CB101	Standard 2.5" x 10"		18	10	56,781 L
20"	CB952	Standard 2.5" x 20"	cyst reduction*	28	0.5	170,343 L
	CB052	Standard 2.5" x 20"		30	5	140,060 L
	CB102	Standard 2.5" x 20"		32	10	132,489 L
10"	CB95MP1	MaxiPlus™ 4.5" x 10"	cyst reduction*	20	0.5	264,978 L
	CB05MP1	MaxiPlus™ 4.5" x 10"		24	5	227,124 L
	CB10MP1	MaxiPlus™ 4.5" x 10"		30	10	196,841 L
20"	CB95MP2	MaxiPlus™ 4.5" x 20"	cyst reduction*	40	0.5	567,811 L
	CB05MP2	MaxiPlus™ 4.5" x 20"		48	5	454,249 L
	CB10MP2	MaxiPlus™ 4.5" x 20"		60	10	378,541 L

Notes: *99.9% reduction of Cryptosporidium and Giardia cysts. ~Capacity is dependent on incoming water quality and flow. Puretec recommends that cartridges should be replaced every 6 - 12 months, when the filter has reached its capacity or when taste or odour returns, whichever occurs first.

Puretec water care products are designed, manufactured, and supported by Puretec Pty Ltd, the name you can trust for viable and proven water solutions. The complete range of Puretec products are developed, refined, and made to meet and exceed stringent specifications for the worldwide market. Important Note: Sales of products are subject to our Terms and Conditions, which are available upon request. All specifications, information, and photos are a guide only and are subject to change without notice. Contact Puretec Customer Support to confirm details.

Warning: Please visit puretecgroup.com/instructions to observe essential manufacturer's instructions before use.
Caution: Do not use with microbiologically unsafe water, or water of unknown quality without adequate disinfection before or after the system. *Where line pressure exceeds 500kPa, an approved pressure limiting device must be installed to comply with Australian & New Zealand Plumbing Standards (Ref. AS 3500.1:2021, Clause 3.3.4). Protect from freezing.
 *Micron rating is nominal. Copyright © Puretec Pty Ltd, 2025.

